

Periodical Testing and checking of Meters under SMP No- 34-07 - Progress for the Qtr ending June'15

NAME OF DISCOM-

M.P.Madhya Kshetra V.V.Co. Ltd. Bhopal

Annexure 1

Sl. No.	Consumer Category	TOTAL NO. OF SINGLE PHASE /THREE PHASE METERS DUE FOR PERIODIC CERTIFICATION			Quarterly achieved progress for each quarter of the year 15-16		percentage testing/certification during reporting year 15-16		
		Total no. of meters installed as on 01.04.15	No of meters due for testing Apr.'15 to Mar'16 (as per provision under M.P.Elec. Supply code)	Yearly proposed Target for the year 15-16	Quarterly (June'15 ending) proposed Target	Qtr ending June'15	Total (Apr'15 to Mar'16)	Against the quarterly target	Against the total no of meters to be tested during the year 15-16
1	2	3	4	5	6	7	10	11	12
A	<u>HT</u>								
1	Bhopal	1266	1266	1266	317	335	335	106%	26%
2	Gwalior	616	616	616	154	157	157	102%	25%
	Central Discom	1882	1882	1882	471	492	492	105%	26%
B	<u>LT</u>								
	<i>1.Single Phase</i>								
1	Bhopal	1356957	271391	271391	67848	35302	35302	52%	13%
2	Gwalior	929736	185947	185947	46487	30682	30682	66%	17%
	Central Discom	2286693	457339	457339	114335	65984	65984	58%	14%
	<i>2.Three Phase</i>								
1	Bhopal	140077	28015	28015	7004	9122	9122	130%	33%
2	Gwalior	59382	11876	11876	2969	2472	2472	83%	21%
	Central Discom	199459	39892	39892	9973	11594	11594	116%	29%
	DISCOM (H.T.+ L.T.)	2488034	499112	499112	124778	78070	78070	63%	16%

As per MPERC order 2013

LT single phase meter = once in every 5 years

LT three phase meter = once in every 5 years (As per supply code 2013)

HT meter = once a year

Addl. GENERAL MANAGER (COM.II)
O/O MD (CZ), MPMKVCL, BHOPAL