

**Periodical Testing and checking of Meters under SMP No- 34-07 - Progress for the Qtr ending March'15**

**NAME OF DISCOM- M.P.Madhya Kshetra V.V.Co. Ltd. Bhopal**

**Annexure 1**

Sl. No.	Consumer Category	TOTAL NO. OF SINGLE PHASE /THREE PHASE METERS DUE FOR PERIODIC CERTIFICATION			Quarterly (Mar.'15 ending) proposed Target	Quarterly achieved progress for each quarter of the year 14-15					percentage testing/certification during reporting year 14-15	
		Total no. of meters installed as on 01.04.14	No of meters due for testing Apr.'14 to Mar'15 (as per provision under M.P.Elec. Supply code)	Yearly proposed Target for the year 14-15		Qtr ending June'14	Qtr ending Sept.'14	Qtr ending Dec.'14	Qtr. ending Mar'15	Total (Apr'14 to Mar'15)	Against the quarterly target	Against the total no of meters to be tested during the year 14-15
1	2	3	4	5	6	7	8	9	13	10	11	12
A	<u>HT</u>											
1	Bhopal	1186	1186	1186	297	368	280	250	288	1186	97%	100%
2	Gwalior	549	549	549	137	146	118	128	115	507	84%	92%
	<b>Central Discom</b>	<b>1735</b>	<b>1735</b>	<b>1735</b>	<b>434</b>	<b>514</b>	<b>398</b>	<b>378</b>	<b>403</b>	<b>1693</b>	<b>93%</b>	<b>98%</b>
B	<u>LT</u>											
	<i>1.Single Phase</i>											
1	Bhopal	1255359	251072	251072	62768	27881	44705	46157	58876	177619	94%	71%
2	Gwalior	859079	171816	171816	42954	40279	29376	32269	34449	136373	80%	79%
	<b>Central Discom</b>	<b>2114438</b>	<b>422888</b>	<b>422888</b>	<b>105722</b>	<b>68160</b>	<b>74081</b>	<b>78426</b>	<b>93325</b>	<b>313992</b>	<b>88%</b>	<b>74%</b>
	<i>2.Three Phase</i>											
1	Bhopal	130756	26151	26151	6538	8687	9645	5625	1748	25705	27%	98%
2	Gwalior	59563	11913	11913	2978	4028	2002	2766	2313	11109	78%	93%
	<b>Central Discom</b>	<b>190319</b>	<b>38064</b>	<b>38064</b>	<b>9516</b>	<b>12715</b>	<b>11647</b>	<b>8391</b>	<b>4061</b>	<b>36814</b>	<b>43%</b>	<b>97%</b>
	<b>DISCOM (H.T.+ L.T.)</b>	<b>2306492</b>	<b>462686</b>	<b>462686</b>	<b>115672</b>	<b>81389</b>	<b>86126</b>	<b>87195</b>	<b>97789</b>	<b>352499</b>	<b>85%</b>	<b>76%</b>

As per MPERC order 2013

LT single phase meter = once in every 5 years

LT three phase meter = once in every 5 years (As per supply code 2013)

HT meter = once a year

**Dy. GENERAL MANAGER (COM.II)**  
O/O MD (CZ), MPMKVCL, BHOPAL