

Periodical Testing and checking of Meters under SMP No- 34-07 - Progress for the Qtr ending June'13

NAME OF DISCOM- M.P.Madhya Kshetra V.V.Co. Ltd. Bhopal

Annexure 1

Sl. No.	Consumer Category	TOTAL NO. OF SINGLE PHASE /THREE PHASE METERS DUE FOR PERIODIC CERTIFICATION			Quarterly achieved progress for each quarter of the year 13-14			percentage testing/certification during reporting year 13-14	
		Total no. of meters installed as on 01.04.13	No of meters due for testing Apr.'13 to Mar'14 (as per provision under M.P.Elec. Supply code)	Yearly proposed Target for the year 13-14	Quarterly (June'13 ending) proposed Target	Qtr ending June'13	Total (Apr'13 to Mar'14)	Against the quarterly target	Against the total no of meters to be tested during the year 13-14
1	2	3	4	5	6	7	10	11	12
A	<u>HT</u>								
1	Bhopal	1118	1118	1118	280	274	274	98%	25%
2	Gwalior	503	503	503	126	142	142	113%	28%
	Central Discom	1621	1621	1621	405	416	416	103%	26%
B	<u>LT</u>								
	<i>1.Single Phase</i>								
1	Bhopal	1127796	225559	225559	56390	43984	43984	78%	19%
2	Gwalior	785567	157113	157113	39278	19811	19811	50%	13%
	Central Discom	1913363	382673	382673	95668	63795	63795	67%	17%
	<i>2.Three Phase</i>								
1	Bhopal	194150	64717	64717	16179	13104	13104	81%	20%
2	Gwalior	65124	21708	21708	5427	3925	3925	72%	18%
	Central Discom	259274	86425	86425	21606	17029	17029	79%	20%
	DISCOM (H.T.+ L.T.)	2174258	470718	470718	117680	81240	81240	69%	17%

As per MPERC order dated 05-09-2008

LT single phase meter = once in every 5 years

LT three phase meter = once in every 3 years

HT meter = once a year

GENERAL MANAGER (COM.II)
O/O MD (CZ), MPMKVCL, BHOPAL