

**Periodical Testing and checking of Meters under SMP No- 34-07 - Progress for the Qtr ending June'14**

**NAME OF DISCOM- M.P.Madhya Kshetra V.V.Co. Ltd. Bhopal**

**Annexure 1**

Sl. No.	Consumer Category	TOTAL NO. OF SINGLE PHASE /THREE PHASE METERS DUE FOR PERIODIC CERTIFICATION			Quarterly achieved progress for each quarter of the year 14-15			percentage testing/certification during reporting year 14-15	
		Total no. of meters installed as on 01.04.14	No of meters due for testing Apr.'14 to Mar'15 (as per provision under M.P.Elec. Supply code)	Yearly proposed Target for the year 14-15	Quarterly (June'14 ending) proposed Target	Qtr ending June'14	Total (Apr'14 to Mar'15)	Against the quarterly target	Against the total no of meters to be tested during the year 14-15
1	2	3	4	5	6	7	10	11	12
A	<u>HT</u>								
1	Bhopal	1186	1186	1186	297	368	368	124%	31%
2	Gwalior	549	549	549	137	146	146	106%	27%
	<b>Central Discom</b>	<b>1735</b>	<b>1735</b>	<b>1735</b>	<b>434</b>	<b>514</b>	<b>514</b>	<b>119%</b>	<b>30%</b>
B	<u>LT</u>								
	<i>1.Single Phase</i>								
1	Bhopal	1255359	251072	251072	62768	27881	27881	44%	11%
2	Gwalior	859079	171816	171816	42954	40279	40279	94%	23%
	<b>Central Discom</b>	<b>2114438</b>	<b>422888</b>	<b>422888</b>	<b>105722</b>	<b>68160</b>	<b>68160</b>	<b>64%</b>	<b>16%</b>
	<i>2.Three Phase</i>								
1	Bhopal	130756	26151	26151	6538	8687	8687	133%	33%
2	Gwalior	59563	11913	11913	2978	4028	4028	135%	34%
	<b>Central Discom</b>	<b>190319</b>	<b>38064</b>	<b>38064</b>	<b>9516</b>	<b>12715</b>	<b>12715</b>	<b>134%</b>	<b>33%</b>
	<b>DISCOM (H.T.+ L.T.)</b>	<b>2306492</b>	<b>462686</b>	<b>462686</b>	<b>115672</b>	<b>81389</b>	<b>81389</b>	<b>70%</b>	<b>18%</b>

As per MPERC order 2013

LT single phase meter = once in every 5 years

LT three phase meter = once in every 5 years (As per supply code 2013)

HT meter = once a year

**GENERAL MANAGER (COM.II)**  
O/O MD (CZ), MPMKVCL, BHOPAL