

Periodical Testing and checking of Meters under SMP No- 34-07 - Progress for the Qtr ending Sept.'14

NAME OF DISCOM- M.P.Madhya Kshetra V.V.Co. Ltd. Bhopal

Annexure 1

Sl. No.	Consumer Category	TOTAL NO. OF SINGLE PHASE /THREE PHASE METERS DUE FOR PERIODIC CERTIFICATION			Quarterly achieved progress for each quarter of the year 14-15			percentage testing/certification during reporting year 14-15		
		Total no. of meters installed as on 01.04.14	No of meters due for testing Apr.'14 to Mar'15 (as per provision under M.P.Elec. Supply code)	Yearly proposed Target for the year 14-15	Quarterly (Sept.'14 ending) proposed Target	Qtr ending June'14	Qtr ending Sept.'14	Total (Apr'14 to Mar'15)	Against the quarterly target	Against the total no of meters to be tested during the year 14-15
1	2	3	4	5	6	7	8	10	11	12
A	<u>HT</u>									
1	Bhopal	1186	1186	1186	297	368	280	648	94%	55%
2	Gwalior	549	549	549	137	146	118	264	86%	48%
	Central Discom	1735	1735	1735	434	514	398	912	92%	53%
B	<u>LT</u>									
	<i>1.Single Phase</i>									
1	Bhopal	1255359	251072	251072	62768	27881	44705	72586	71%	29%
2	Gwalior	859079	171816	171816	42954	40279	29376	69655	68%	41%
	Central Discom	2114438	422888	422888	105722	68160	74081	142241	70%	34%
	<i>2.Three Phase</i>									
1	Bhopal	130756	26151	26151	6538	8687	9645	18332	148%	70%
2	Gwalior	59563	11913	11913	2978	4028	2002	6030	67%	51%
	Central Discom	190319	38064	38064	9516	12715	11647	24362	122%	64%
	DISCOM (H.T.+ L.T.)	2306492	462686	462686	115672	81389	86126	167515	74%	36%

As per MPERC order 2013

LT single phase meter = once in every 5 years

LT three phase meter = once in every 5 years (As per supply code 2013)

HT meter = once a year

GENERAL MANAGER (COM.II)
O/O MD (CZ), MPMKVCL, BHOPAL